

CERTIFICATE

TÜV NORD CERT GmbH
herewith declares that

Changzhou EGing Photovoltaic Technology Co., Ltd.
No.18 Jinwu Road, Yaotang Town, Jintan City
Jiangsu Province, 213213
P.R.China

is authorized to provide the product mentioned below with the mark as illustrated:

Description of product (details see Annex 2):

PV Modules with 6" Poly-crystalline Silicon Solar Cells

Tested according to: IEC 61215-1:2016;
IEC 61215-1-1:2016;
IEC 61215-2:2016;
IEC 61730-1:2016;
IEC 61730-2:2016.

Registered No.: 44 780 18 406749 - 264
Manufacturer: see Annex 1
Test Report No.: 492011101.001
File No.: SHV12061/17-01



Valid from: 2018-09-11
Valid until: 2023-09-10



TÜV NORD CERT GmbH
Certification Body
Consumer Products



Essen, 2018-09-11

Please also pay attention to the information stated overleaf.

Anlage 1 zum Zertifikat Nr.: / Annex 1 to Certificate No.: 44 780 18 406749 - 264

Aktenzeichen: / File reference: SHV12061/17-01

Seite / Page 1 von / of 1

2018-09-11

Manufacturer:

Manufacturer:

Changzhou EGing Photovoltaic Technology Co., Ltd.

No.18 Jinwu Road, Yaotang Town, Jintan City

Jiangsu Province 213213, P.R.China

Factory inspection report no.:

862010123.006

Remark:

Factory inspection is mandatory to be performed annually. Please refer to factory inspection report for detailed information.



TÜV NORD CERT GmbH
Certification Body
Consumer Products

Description of product(s):

Module types:	PV Modules with 6" Poly-crystalline Silicon Solar Cells: 72 cells: EG-xxxP72-C (xxx = 310-340, in increment of 5) 60 cells: EG-xxxP60-C (xxx = 260-285, in increment of 5) 54 cells: EG-xxxP54-C (xxx = 235-255, in increment of 5) 48 cells: EG-xxxP48-C (xxx = 210-225, in increment of 5)
Maximum system voltage:	1000V
Fuse rating:	15A
Electrical protection class:	Class II
Pollution degree:	1 for some combinations of materials, 2 for others. See CDF for details
Material group:	I
Design load:	2400Pa (upward) / 2400Pa (downward)
Safety factors:	1.5
Fire safety class:	Class C

Remark:

For detailed product information, please refer to CDF (Constructional Data Form) in Annex 1 of test report.



TÜV NORD CERT GmbH
Certification Body
Consumer Products

CERTIFICATE

TÜV NORD CERT GmbH
herewith declares that

Changzhou EGing Photovoltaic Technology Co., Ltd.
No.18 Jinwu Road, Yaotang Town, Jintan City
Jiangsu Province, 213213
P.R.China

is authorized to provide the product mentioned below with the mark as illustrated:

Description of product (details see Annex 2):

PV Modules with 6" Mono-crystalline Silicon Solar Cells

Tested according to: IEC 61215-1:2016;
IEC 61215-1-1:2016;
IEC 61215-2:2016;
IEC 61730-1:2016;
IEC 61730-2:2016.

Registered No.: 44 780 18 406749 - 263
Manufacturer: see Annex 1
Test Report No.: 492011101.001
File No.: SHV12061/17-01



Valid from: 2018-09-11
Valid until: 2023-09-10



TÜV NORD CERT GmbH
Certification Body
Consumer Products



Essen, 2018-09-11

Please also pay attention to the information stated overleaf.

Anlage 1 zum Zertifikat Nr.: / Annex 1 to Certificate No.: 44 780 18 406749 - 263

Seite / Page 1 von / of 1

Aktenzeichen: / File reference: SHV12061/17-01

2018-09-11

Manufacturer:

Manufacturer: **Changzhou EGing Photovoltaic Technology Co., Ltd.**
No.18 Jinwu Road, Yaotang Town, Jintan City
Jiangsu Province 213213, P.R.China

Factory inspection report no.: 862010123.006

Remark:

Factory inspection is mandatory to be performed annually. Please refer to factory inspection report for detailed information.



TÜV NORD CERT GmbH
Certification Body
Consumer Products

Description of product(s):

Module types:	PV Modules with 6" Mono-crystalline Silicon Solar Cells: 72 cells: EG-xxxM72-C (xxx = 330-365, in increment of 5) 60 cells: EG-xxxM60-C (xxx = 275-305, in increment of 5) 54 cells: EG-xxxM54-C (xxx = 250-270, in increment of 5) 48 cells: EG-xxxM48-C (xxx = 220-240, in increment of 5)
Maximum system voltage:	1000V
Fuse rating:	15A
Electrical protection class:	Class II
Pollution degree:	1 for some combinations of materials, 2 for others. See CDF for details
Material group:	I
Design load:	2400Pa (upward) / 2400Pa (downward)
Safety factors:	1.5
Fire safety class:	Class C

Remark:

For detailed product information, please refer to CDF (Constructional Data Form) in Annex 1 of test report.



TÜV NORD CERT GmbH
Certification Body
Consumer Products