

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
PV 50400244

Blatt *Sheet*
0001

Ihr Zeichen <i>Client Reference</i>	Unser Zeichen <i>Our Reference</i>	Ausstellungsdatum <i>Date of Issue</i>
Y.H.C.	01-FLY-50116992 001	30.03.2018 <i>(day/mo/yr)</i>

Genehmigungsinhaber <i>License Holder</i>	Fertigungsstätte <i>Manufacturing Plant</i>
Changzhou EGing Photovoltaic Technology Co., Ltd. No.18 Jinwu Road, Yaotang Town Jintan City, Jiangsu Province 213213 P. R. China	Changzhou EGing Photovoltaic Technology Co., Ltd. No.18 Jinwu Road, Yaotang Town Jintan City, Jiangsu Province 213213 P. R. China

Prüfzeichen *Test Mark*



IEC 61215
IEC 61730
Regular Production
Surveillance

www.tuv.com
ID 1419055371

Geprüft nach *Tested acc. to*

IEC 61215-1:2016
IEC 61215-1-1:2016
IEC 61215-2:2016
IEC 61730-1:2016
IEC 61730-2:2016

Zertifiziertes Produkt (Geräteidentifikation) *Certified Product (Product Identification)*

Lizenzentgelte - Einheit *License Fee - Unit*

PV Module

Type Designation:

With 6" mono c-Si cells:

EG-XXXM72-C (xxx=330-365, in steps of 5, 72 cells)
EG-XXXM60-C (xxx=275-305, in steps of 5, 60 cells)
EG-XXXM54-C (xxx=250-270, in steps of 5, 54 cells)
EG-XXXM48-C (xxx=220-240, in steps of 5, 48 cells)

With 6" poly c-Si cells:

EG-XXXP72-C (xxx=310-340, in steps of 5, 72 cells)
EG-XXXP60-C (xxx=260-285, in steps of 5, 60 cells)
EG-XXXP54-C (xxx=235-255, in steps of 5, 54 cells)
EG-XXXP48-C (xxx=210-225, in steps of 5, 48 cells)

Remarks:

Class II acc. to IEC 61140
Max. System Voltage: up to 1000 VDC (Voc at STC)
Fire Rating: Class C
Pollution Degree: 1
Design Load/ Safety Factors: 2400 Pa / 1.5 (downward)
2400 Pa / 1.5 (upward)

Continued on Page 2

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.
Das Produkt entspricht den o.g. Anforderungen, die Herstellung wird überwacht.
This certificate is based on our Testing and Certification Regulation. The product fulfills above mentioned requirements, the production is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety



Zertifizierungsstelle

Dipl.-Ing. D. Löffler

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
PV 50400244

Blatt *Sheet*
0002

Ihr Zeichen *Client Reference*
Y.H.C.

Unser Zeichen *Our Reference*
01-FLY-50116992 001

Ausstellungsdatum *Date of Issue*
30.03.2018 (day/mo/yr)

Genehmigungsinhaber *License Holder*

Changzhou EGing Photovoltaic
Technology Co., Ltd.
No.18 Jinwu Road, Yaotang Town
Jintan City, Jiangsu Province 213213
P. R. China

Fertigungsstätte *Manufacturing Plant*

Changzhou EGing Photovoltaic
Technology Co., Ltd.
No.18 Jinwu Road, Yaotang Town
Jintan City, Jiangsu Province 213213
P. R. China

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*

IEC 61215-1:2016
IEC 61215-1-1:2016
IEC 61215-2:2016
IEC 61730-1:2016
IEC 61730-2:2016

**Zertifiziertes Produkt (Geräteidentifikation)
*Certified Product (Product Identification)***

**Lizenzentgelte - Einheit
*License Fee - Unit***

PV Module

Continuation of Page 1

4

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

Validity: 5 years counting from date of issue.

4

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.
Das Produkt entspricht den o.g. Anforderungen, die Herstellung wird überwacht.
This certificate is based on our Testing and Certification Regulation. The product fulfills above mentioned requirements, the production is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety



Löffler

Dipl.-Ing. D. Löffler